

<b>SOLICITATION/CONTRACT/ORDER FOR COMMERCIAL ITEMS</b> OFFEROR TO COMPLETE BLOCKS 12, 17, 23, 24, & 30			1. REQUISITION NUMBER PR5645601		PAGE 1 OF 3
2. CONTRACT NO.		3. AWARD/EFFECTIVE DATE	4. ORDER NUMBER	5. SOLICITATION NUMBER S-JO100-16-Q-0047	6. SOLICITATION ISSUE DATE 08/29/2016
7. FOR SOLICITATION INFORMATION CALL		a. NAME Mahmoud Itani		b. TELEPHONE NUMBER(No collect calls) (962) 6 590-6133	8. OFFER DUE DATE/ LOCAL TIME 16:00, 09/13/2016
9. ISSUED BY  General Services Office American Embassy P. O. Box 354 Amman - Jordan  Tel: (962) 6 590-6026 Fax: (962) 6 590-6888		CODE	10. THIS ACQUISITION IS <input checked="" type="checkbox"/> UNRESTRICTED <input type="checkbox"/> SET ASIDE: % FOR <input type="checkbox"/> SMALL BUSINESS  <input type="checkbox"/> HUBZONE SMALL BUSINESS <input type="checkbox"/> 8(A)  NAICS: SIZE STD:	11. DELIVERY FOR FOB DESTINATION UNLESS BLOCK IS MARKED <input type="checkbox"/> SEE SCHEDULE  <input type="checkbox"/> 13a. THIS CONTRACT IS A RATED ORDER UNDER DPAS (15 CFR 700)  13b. RATING  14. METHOD OF SOLICITATION <input checked="" type="checkbox"/> RFQ <input type="checkbox"/> IFB <input type="checkbox"/> RFP	12. DISCOUNT TERMS
15. DELIVER TO  American Embassy Amman - Jordan		CODE	16. ADMINISTERED BY  CODE		
17a. CONTRACTOR/OFFEROR CODE		FACILITY CODE	18a. PAYMENT WILL BE MADE BY  Financial Management Office (FMO) American Embassy P. O. Box 354 Amman - Jordan TELEPHONE NO.		
<input type="checkbox"/> 17b. CHECK IF REMITTANCE IS DIFFERENT AND PUT SUCH ADDRESS IN OFFER			<input type="checkbox"/> 18b. SUBMIT INVOICES TO ADDRESS SHOWN IN BLOCK 18a UNLESS BLOCK BELOW IS CHECKED <input type="checkbox"/> SEE ADDENDUM		
19. ITEM NO.	20. SCHEDULE OF SUPPLIES/SERVICES		21. QUANTITY	22. UNIT	23. UNIT PRICE
1	<u>Supply and install high cube refrigerated container</u>  As per attached description, specifications & work Statement  (Use Reverse and/or Attach Additional Sheets as Necessary)		1	EA	
25. ACCOUNTING AND APPROPRIATION DATA					26. TOTAL AWARD AMOUNT (For Govt. Use Only)
<input checked="" type="checkbox"/> 27a. SOLICITATION INCORPORATES BY REFERENCE FAR 52.212-1, 52.212-4, FAR 52.212-3 AND 52.212-5 ARE ATTACHED. ADDENDA <input checked="" type="checkbox"/> ARE <input type="checkbox"/> ARE NOT ATTACHED.					
<input checked="" type="checkbox"/> 27b. CONTRACT/PURCHASE ORDER INCORPORATES BY REFERENCE FAR 52.212-4. FAR 52.212-5 IS ATTACHED. ADDENDA <input checked="" type="checkbox"/> ARE <input type="checkbox"/> ARE NOT ATTACHED.					
<input type="checkbox"/> 28. CONTRACTOR IS REQUIRED TO SIGN THIS DOCUMENT AND RETURN <u>2</u> COPIES TO ISSUING OFFICE. CONTRACTOR AGREES TO FURNISH AND DELIVER ALL ITEMS SET FORTH OR OTHERWISE IDENTIFIED ABOVE AND ON ANY ADDITIONAL SHEETS SUBJECT TO THE TERMS AND CONDITIONS SPECIFIED HEREIN.			<input type="checkbox"/> 29. AWARD OF CONTRACT: REF. _____ OFFER DATED _____. YOUR OFFER ON SOLICITATION (BLOCK 5), INCLUDING ANY ADDITIONS OR CHANGES WHICH ARE SET FORTH HEREIN, IS ACCEPTED AS TO ITEMS:		
30a. SIGNATURE OF OFFEROR/CONTRACTOR			31a. UNITED STATES OF AMERICA (SIGNATURE OF CONTRACTING OFFICER)		
30b. NAME AND TITLE OF SIGNER (TYPE OR PRINT)		30c. DATE SIGNED	31b. NAME OF CONTRACTING OFFICER (Type or Print) Shayna Michael		31c. DATE SIGNED

## Replacing Commissary walk-in freezer

### Section 1 :Required Specification:

The embassy required vendor to supply and install high cube refrigerated container, with the below requirements:

- 1) 40 feet SEACO high cube refrigerated container or equivalent
- 2) Dimensions: internal length 38 ft. X internal width 7ft. 4 inch' X internal height 8Ft. 4 inch (40 foot container)
- 3) Outdoor installation, the room and refrigerant system will be installed out door; therefore the systems should be installed according mechanical and electrical codes with proper insulation.
- 4) Walk-in Door right-hand swing door, padlock handle with inside release magnetic.
- 5) Carrier (or equivalent) refrigeration unit reaching -18 to 2 Degrees Celsius, Low Temperature, Air Cooled, R -134A (or equivalent) Refrigerant and Defrost Timer".
- 6) Exceptional efficiency and life-cycle cost.
- 7) Ambient Control Kit (Includes Head Pressure Control and Crankcase Heater)"
- 8) Remote Refrigeration System Includes Drier, Sight Glass "
- 9) Construction Approvals: NSF Approved, cULus and CSA Electrical, UL Flame Spread25 and ULC Flame Spread50 in Accordance with ASTM-" Wall insulation 10cm thickness minimum, sandwich panel insulation on ceiling, walls and floor.
- 10) Supplied with lighting, condenser, evaporator & control panel.
- 11) Unit ready to be plugged into an electrical power source 380v or 220v/50hz
- 12) Control panel and freezer room door, with louvers on Sides".
- 13) Minimum 12 months warranty
- 14) Two outdoor units, main and standby unit.
- 15) Protections: Low pressure, high pressure lube oil pressure overvoltage, phase failure temperature gauges with alarm alert.
- 16) External shades over the door for protection from rain and sun.
- 17) Floor panel is covered by anti-slip stainless steel sheet.
- 18) Energy efficient systems and design.
- 19) Digital thermometer visible outside the container.
- 20) Outdoor units should be provided with Oil separator, Accumulator, and reservoir.

**Section 2: Submittals needed with the offer:**

- 1) A Sketch and drawing of the unit to include a pictures.
- 2) Type of the insulation to include the MSDS
- 3) Refrigeration type and specification.
- 4) Compressor type, Model, preferred save energy types.
- 5) Unit full specification to include atmosphere temperature for max and min.
- 6) Warranty.
- 7) Service support in Jordan-Amman
- 8) Delivery time (lead time).

