

Q1: Hyperlinks: The hyperlinks in the solicitation for safety and other standards do not seem to have a linked reference. Would it be possible to share such documentation in PDF format? (Contractor General Responsibilities, Barricading & Fencing, Electrical Safety, Lockout/Tagout, Fall Protection, Hazard Communications, Hand and Power Tool Safety, Scaffolding, Noise, Hot Work Permit, Trenching & Excavations).

A1: Kindly find attached file for the “Construction Safety Regulations at the U.S. Embassy, Amman” that includes a combined PDF format with all above mentioned subjects.

Q2: Polycarbonate Sheet Specifications: Would 9.5mm thickness be acceptable, provided a 10 year warranty will be extended.

A2: Kindly comply with the specification mentioned in the SOW.

Q3: Existing Timber Beams: Kindly provide us with the section size and material specification (wood type) of the existing timber beams.

A3:

- The existing section size is 4”x10” for the timbers and 2”x10” for joists.
- Existing Wood Specifications:
 - Density: 22lb/Ft³
 - Specific gravity: 0.35
 - Durability: Durable species
 - Fasteners: Corrosion resistant only (stainless steel, aluminum, hot-dipped galvanized, brass, etc.)
 - Flame spread rating: 69(class II)
 - Smoke developed classification: 98
 - K value (12% mc): 0.74 BTU in.per square ft.h degrees F
 - Wood color : charwood

However, the offeror shall provide submittal for the proposed material reflecting section details and material specification.